



**HOPE ACADEMY CHARTER SCHOOLS  
LEAD IN DRINKING WATER  
FLUSH DRAW SAMPLING REPORT**

*PERFORMED FOR:*

**HOPE ACADEMY CHARTER SCHOOLS  
601 GRAND AVENUE  
ASBURY PARK, NJ 07712**

*PERFORMED BY:*

**WESTCHESTER ENVIRONMENTAL LLC  
1248 WRIGHTS LANE  
WEST CHESTER, PA 19380**

JANUARY 2021



January 7, 2022

Mr. Ahmed Lawson  
Hope Academy Charter Schools  
601 Grand Avenue  
Asbury Park, NJ 07712

**Re: FIRST & FLUSH DRAW LEAD IN DRINKING WATER REPORT**

Dear Mr. Lawson,

Please find enclosed the report for the Lead in Drinking Water Flush Draw Sampling conducted for the Hope Academy Charter Schools.

If you have any questions, please don't hesitate to contact me at 610-431-7545 or email me at [nabraham@WestChesterEnvironmental.com](mailto:nabraham@WestChesterEnvironmental.com).

Sincerely,

Westchester Environmental, LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', is written over a horizontal line.

Noel Abraham  
Environmental Specialist



# TABLE OF CONTENTS

## HOPE ACADEMY CHARTER SCHOOLS

1.0	INTRODUCTION.....	1
2.0	SUMMARY OF FINDINGS.....	2
3.0	SAMPLING AND ANALYSES.....	4
4.0	DISCUSSION & RECOMMENDATIONS.....	5
5.0	DISCLAIMER.....	6

Appendix I – Water Sampling Chains-of-Custody & Laboratory Reports



## 1.0 INTRODUCTION

Westchester Environmental, LLC was contracted by Mr. Ahmed Lawson to conduct Drinking Water Sampling at the following Hope Academy Charter School buildings:

1. 601 Grand Ave, Asbury Park, NJ
2. 500 Grand Ave, Asbury Park, NJ

The purpose of the sampling was to collect first draw and flush draw drinking water samples at predetermined locations in the two facilities and have them analyzed for lead levels.

The water sampling was performed on November 2, 2021 by Noel Abraham of Westchester Environmental, LLC.

All samples were analyzed by Suburban Testing Labs located at 1037 MacArthur Rd, Reading, PA 19605, a New Jersey certified Lead in Drinking Water testing facility.

*-END OF SECTION-*



## 2.0 SUMMARY OF FINDINGS

First Draw samples were collected and submitted for lead analysis. Tables 1-2 below shows the concentration of lead (parts per billion or microgram per liter) at each location sampled.

Table 1: 601 Grand Ave

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
1	HACS-1FL-POE-Faculty BR	<1.00	15.5	No
2	HACS-1FL-S-Boys RR	5.08	15.5	No
3	HACS-1FL-S-Girls RR	3.28	15.5	No
4	HACS-1FL-WC-Hall o/s 101	2.71	15.5	No
5	HACS-2FL-S-Boys RR-1	2.73	15.5	No
6	HACS-2FL-S-Boys RR-2	3.22	15.5	No
7	HACS-2FL-S-Boys RR-3	2.92	15.5	No
8	HACS-2FL-S-Girls RR-1	2.87	15.5	No
9	HACS-2FL-S-Girls RR-2	3.28	15.5	No
10	HACS-2FL-S-Girls RR-3	2.55	15.5	No
11	HACS-2FL-FS-Rm 206	2.19	15.5	No
12	HACS-2FL-WC-Hall o/s 206-1	<1.00	15.5	No
13	HACS-2FL-WC-Hall o/s 206-2	<1.00	15.5	No
14	HACS-2FL-S-Sink 208	6.50	15.5	No
15	HACS-3FL-S-Boys RR-1	3.35	15.5	No
16	HACS-3FL-S-Boys RR-2	4.53	15.5	No
17	HACS-3FL-S-Boys RR-3	3.56	15.5	No
18	HACS-3FL-S-Girls RR-1	4.80	15.5	No
19	HACS-3FL-S-Girls RR-2	4.88	15.5	No
20	HACS-3FL-S-Girls RR-3	3.11	15.5	No
21	HACS-3FL-WC-Hall o/s Boy's RR	1.06	15.5	No
22	HACS-4FL-S-Boys RR	4.42	15.5	No
23	HACS-4FL-S-Girls RR	1.50	15.5	No
24	HACS-4FL-KS-Kitchen	3.59	15.5	No
25	HACS-5FL-S-Boys RR	5.70	15.5	No
26	HACS-5FL-S-Girls RR	8.20	15.5	No



Table 2: 500 Grand Ave

	Location Code	Result (ppb)	Action Level (ppb)	Lead Hazard (Yes/No)
27	HACS-1FL-POE-Boiler Room	<1.00	15.5	No
28	HACS-1FL-S-O/S Janitors Closet	4.36	15.5	No
29	HACS-1FLS-Womens BR	3.57	15.5	No
30	HACS-1FL-S-Mens BR	3.42	15.5	No
31	HACS-1FL-NS-Nurse	13.6	15.5	No
32	HACS-1FL-S-Rm 206	15.7	15.5	Yes
33	HACS-2FL-S-Mens BR	15.6	15.5	Yes
34	HACS-2FL-S-Womens BR	3.52	15.5	No
35	HACS-2FL-S-MPR	4.78	15.5	No
36	Field Blank	<1.00	15.5	No

In instances where the first draw exceeded the action level, the corresponding flush draw sample was activated for analysis. Tables 3 compares the results of the flush sample to its corresponding first draw sample and also compares the FLUSH samples against the lead action limit. Those samples that exceeded the lead action limit are yellow highlighted in these tables.

Table 3 500 Grand Ave

	Location Code	First Draw Result (ppb)	Flush Draw Result (ppb)	Action Level (ppb)
1	HACS-1FL-S-Rm 206	15.7	<1.00	15.5
	HACS-2FL-S-Mens BR	15.6	1.71	15.5

*-END OF SECTION-*



### 3.0 SAMPLING AND ANALYSES

The following guidance documents were followed for all sampling:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Thirty five (35) draw and flush draw samples, along with one field blank for quality control purposes, were collected. All first draw samples were analyzed. Flush samples were held by the lab pending first draw results and then activated for locations with first draw exceedances.

All samples were labeled with a unique identification number and transported to the Suburban Laboratory for analysis for lead in drinking water using EPA Method 200.8.

*-END OF SECTION-*



## 4.0 DISCUSSION & RECOMMENDATIONS

According to the US EPA, lead enters drinking water primarily through plumbing materials.

For further information on guidance protocols and Action Levels that were followed please refer to:

1. N.J.A.C. 6A:26
2. The EPA's Revised Technical Guidance - "3Ts for Reduced Lead in Drinking Water in Schools"
3. Guidance Document from NJDEP Division of Water Supply and Geoscience – "Lead in Drinking Water: Guidance for Schools and Child Care Facilities Served by Public Water".

Based on laboratory analysis of the samples analyzed, two (2) first draw samples exceeded the action limit. Their corresponding flush draw samples fell below the action limit.

### **Immediate / Short Term Action Required:**

1. Immediately discontinue using water at locations where the two first draw samples exceeded the NJDEP 15.5 ppb Action Level. If those locations are going to be remediated for future use they will need to be re-tested prior to being put in service to make sure the remedial work was successful.
2. Refer to EPA's "**for Reducing Lead in Drinking Water in Schools and Child Care Facilities**" for other short term and long term suggested remediation measures and notification procedures.

The type of samples collected for this assessment are referred to as grab samples. Grab samples are individual discrete samples collected at a specific time and location and are reflective of the conditions at that time of collection.

It is important to note that the Lead Hazard Assessment was a snap shot of the conditions existing at the time of the assessment and conditions may vary with time.

*-END OF SECTION-*





## 5.0 DISCLAIMER

The Lead Hazard Assessment has limitations with regards to identification of actual health and environmental issues. It is limited to only those items listed in the report and all items reflect conditions at the time of the assessment only.

Westchester Environmental LLC warrants only that the contents of this report constitute an informed discussion of the assessment at the subject property and is prepared exclusively for, and is confidential to, the above noted client. Westchester Environmental LLC assumes no liability with regards to the use of this information or decisions, which are made regarding the subject property. The user(s) of this information must use their own best judgment to determine the appropriate course of action.

Westchester Environmental LLC

A handwritten signature in black ink, appearing to read 'Noel Abraham', followed by a horizontal line.

Noel Abraham  
Environmental Specialist

*-END OF REPORT-*

## **APPENDIX I**

**LEAD IN DRINKING WATER SAMPLING  
CHAINS-OF-CUSTODY & LAB REPORTS**



### Results Report

Order ID: 1K03012

Westchester Environmental  
1248 Wrights Lane  
West Chester, PA 19380

Project: Hope Academy Center - 500

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1K03012-01	Site: HACS-1FL-POE-Boiler Room	Sample ID: Cafe-1
Collector: NPA	Collect Date: 11/02/2021 11:10 am	Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:37	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-02	Site: HACS-1FL-S-O/S Janitors Closet	Sample ID: O/S Janitors Closet
Collector: NPA	Collect Date: 11/02/2021 11:12 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.36	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:39	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-03	Site: HACS-1FLS-Womens BR	Sample ID: Womens BR
Collector: NPA	Collect Date: 11/02/2021 11:13 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.57	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:41	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-04	Site: HACS-1FL-S-Mens BR	Sample ID: Mens BR
Collector: NPA	Collect Date: 11/02/2021 11:14 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.42	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:33	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-05	Site: HACS-1FL-NS-Nurse	Sample ID: Nurse
Collector: NPA	Collect Date: 11/02/2021 11:15 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	13.6	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:45	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/17/2021 3:27 pm      1K03012  
 STL\_Results    Revision #1.9      Effective: 04/16/2020





Sample Number: 1K03012-06	Site: HACS-1FL-S-Rm 206	Sample ID: Rm 206
Collector: NPA	Collect Date: 11/02/2021 11:16 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.7	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:47	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-07	Site: HACS-2FL-S-Mens BR	Sample ID: Mens BR
Collector: NPA	Collect Date: 11/02/2021 11:17 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	15.6	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:52	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-08	Site: HACS-2FL-S-Womens BR	Sample ID: Womens BR
Collector: NPA	Collect Date: 11/02/2021 11:18 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.52	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 14:58	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-09	Site: HACS-2FL-S-MPR	Sample ID: Multi Purpose Room
Collector: NPA	Collect Date: 11/02/2021 11:19 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.78	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:42	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03012-10	Site: Field Blank	Sample ID: Field Blank
Collector: NPA	Collect Date: 11/02/2021 11:20 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	JED	11/16/21 15:44	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

Report Generated On: 11/17/2021 3:27 pm      1K03012  
 STL\_Results Revision #1.9      Effective: 04/16/2020





# SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 11/17/2021 3:27 pm 1K03012  
STL\_Results Revision #1.9 Effective: 04/16/2020





1K03012  
Lisa F. Care



Chain of Custody Record  
1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Hope Academy Charter		
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Hope Academy Charter		
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		500 Grand Ave, Asbury Park, NJ 07712		
Contact Name:	Noel Abraham			Payment / P.O. Info:			

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	HACS-1FL-POE-Boiler Room	11/02/21	11:10 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	Boiler Room
First	HACS-1FL-S-O/S Janitors Closet	11/02/21	11:12 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	O/S Janitors Closet
First	HACS-1FL-S-Womens BR	11/02/21	11:13 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Womens BR
First	HACS-1FL-S-Mens BR	11/02/21	11:14 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Mens BR
First	HACS-1FL-NS-Nurse	11/02/21	11:15 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Nurse
First	HACS-1FL-S-Rm 206	11/02/21	11:16 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Rm 206
First	HACS-2FL-S-Mens BR	11/02/21	11:17 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Mens BR
First	HACS-2FL-S-Womens BR	11/02/21	11:18 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Womens BR
First	HACS-2FL-S-MPR	11/02/21	11:19 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Multi Purpose Room
First	Field Blank	11/02/21	11:20 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Field Blank

Relinquished by: *GNH*

Date:

Time:

Received By: *GNH - GTC*

Date: 11/9/21 Temp °C: 22°C

Time: 12:00 Acceptable Y/N

Relinquished by: *GNH - GTC*

Date: 11/9/21 Temp °C: 19°C

Time: 12:30 Acceptable Y/N

Received in Lab By: *GNH*

Date: 11/9/21 Temp °C: 19°C

Time: 12:30 Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted in COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Submitted in COC <input checked="" type="checkbox"/> Y/N	Dist = Raw Effluent, Distilled, Springs, etc. (reported as mg/L)	G = Glass
Submitted in COC <input checked="" type="checkbox"/> Y/N	PW = Potable Water	C = Other
Submitted in COC <input checked="" type="checkbox"/> Y/N	Dist for SDWA compliance	Preservative Key
Submitted in COC <input checked="" type="checkbox"/> Y/N	SDWA = Safe Drinking Water Act	H = Sodium
Submitted in COC <input checked="" type="checkbox"/> Y/N	Potable Sample	Thiosulfate
All containers closed <input checked="" type="checkbox"/> Y/N	Sample Type Key	Acid
Temp within holding time <input checked="" type="checkbox"/> Y/N	D = Distribution	A = Ascorbic
40 ml VOA subs free of headspace <input checked="" type="checkbox"/> Y/N	H = Entry Point	H = HNO3
	G = Grab	C = HCl
	2 HC = 2 Hour Composite	H2SO4
	C = Check	G = Other
	S = Special	Note Required
	M = Maximum Retention	



### Results Report

Order ID: 1K03014

Westchester Environmental  
1248 Wrights Lane  
West Chester, PA 19380

Project: Hope Academy Charter - 601 Grand  
601 Grand Ave  
Asbury Park, NJ 07712

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1K03014-01	Site: HACS-1FL-POE-Faculty BR	Sample ID: Faculty BR
Collector: NPA	Collect Date: 11/02/2021 10:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:10	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-02	Site: HACS-1FL-S-Boys RR	Sample ID: Boys RR
Collector: NPA	Collect Date: 11/02/2021 10:31 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.08	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:02	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-03	Site: HACS-1FL-S-Girls RR	Sample ID: Girls RR
Collector: NPA	Collect Date: 11/02/2021 10:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.28	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:03	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-04	Site: HACS-1FL-WC-Hall o/s 101	Sample ID: Hall o/s 101
Collector: NPA	Collect Date: 11/02/2021 10:33 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.71	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:05	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-05	Site: HACS-2FL-S-Boys RR-1	Sample ID: Boys RR-1
Collector: NPA	Collect Date: 11/02/2021 10:34 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.73	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:07	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/17/2021 3:26 pm 1K03014  
STL\_Results Revision #1.9 Effective: 04/16/2020





# SUBURBAN TESTING LABS

Sample Number: 1K03014-06	Site: HACS-2FL-S-Boys RR-2	Sample ID: Boys RR-2
Collector: NPA	Collect Date: 11/02/2021 10:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	3.22	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/15/21 15:15	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-07	Site: HACS-2FL-S-Boys RR-3	Sample ID: Boys RR-3
Collector: NPA	Collect Date: 11/02/2021 10:36 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	2.92	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 12:00	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-08	Site: HACS-2FL-S-Girls RR-1	Sample ID: Girls RR-1
Collector: NPA	Collect Date: 11/02/2021 10:37 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	2.87	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 11:52	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-09	Site: HACS-2FL-S-Girls RR-2	Sample ID: Girls RR-2
Collector: NPA	Collect Date: 11/02/2021 10:38 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	3.28	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 11:54	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-10	Site: HACS-2FL-S-Girls RR-3	Sample ID: Girls RR-3
Collector: NPA	Collect Date: 11/02/2021 10:39 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	2.55	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/15/21 15:16	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-11	Site: HACS-2FL-FS-Rm 206	Sample ID: Rm 206
Collector: NPA	Collect Date: 11/02/2021 10:40 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	2.19	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 11:59	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-12	Site: HACS-2FL-WC-Hall o/s 206-1	Sample ID: Hall o/s 206-1
Collector: NPA	Collect Date: 11/02/2021 10:41 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

### Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 11:46	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/17/2021 3:26 pm 1K03014  
 STL\_Results Revision #1.9 Effective: 04/16/2020







Sample Number: 1K03014-13	Site: HAC5-2FL-WC-Hall o/s 206-2	Sample ID: Hall o/s 206-2
Collector: NPA	Collect Date: 11/02/2021 10:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/10/21	TAH	11/12/21 11:51	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-14	Site: HAC5-2FL-S-Sink 208	Sample ID: Sink 208
Collector: NPA	Collect Date: 11/02/2021 10:43 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	6.50	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:25	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-15	Site: HAC5-3FL-S-Boys RR-1	Sample ID: Boys RR-1
Collector: NPA	Collect Date: 11/02/2021 10:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.35	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:47	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-16	Site: HAC5-3FL-S-Boys RR-2	Sample ID: Boys RR-2
Collector: NPA	Collect Date: 11/02/2021 10:45 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.53	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 13:34	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-17	Site: HAC5-3FL-S-Boys RR-3	Sample ID: Boys RR-3
Collector: NPA	Collect Date: 11/02/2021 10:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.56	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:46	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-18	Site: HAC5-3FL-S-Girls RR-1	Sample ID: Girls RR-1
Collector: NPA	Collect Date: 11/02/2021 10:47 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.80	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:39	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-19	Site: HAC5-3FL-S-Girls RR-2	Sample ID: Girls RR-2
Collector: NPA	Collect Date: 11/02/2021 10:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.88	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:38	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/17/2021 3:26 pm      1K03014  
 STL\_Results    Revision #1.9      Effective: 04/16/2020





Sample Number: 1K03014-20	Site: HAC3-3FL-S-Girls RR-3	Sample ID: Girls RR-3
Collector: NPA	Collect Date: 11/02/2021 10:49 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.11	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:36	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-21	Site: HAC3-3FL-WC-Hall o/s Boy's RR	Sample ID: Hall o/s Boy's RR
Collector: NPA	Collect Date: 11/02/2021 10:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.06	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:57	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-22	Site: HAC3-4FL-S-Boys RR	Sample ID: Boys RR
Collector: NPA	Collect Date: 11/02/2021 10:51 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.42	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:55	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-23	Site: HAC3-4FL-S-Girls RR	Sample ID: Girls RR
Collector: NPA	Collect Date: 11/02/2021 10:52 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.50	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:54	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-24	Site: HAC3-4FL-KS-Kitchen	Sample ID: Kitchen
Collector: NPA	Collect Date: 11/02/2021 10:53 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	3.59	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:52	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03014-25	Site: HAC3-5FL-S-Boys RR	Sample ID: Boys RR
Collector: NPA	Collect Date: 11/02/2021 10:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	5.70	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:51	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/17/2021 3:26 pm 1K03014  
 STL\_Results Revision #1.9 Effective: 04/16/2020





Sample Number: 1K03014-26	Site: HACS-5FL-S-Girls RR	Sample ID: Girls RR
Collector: NPA	Collect Date: 11/02/2021 10:55 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Metals</u>									
Lead	8.20	µg/L	EPA 200.8	1.00	1	11/10/21	YBZ	11/16/21 11:49	RPV

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 11/17/2021 3:26 pm 1K03014  
STL\_Results Revision #1.9 Effective: 04/16/2020





1K03014  
Lisa F. Care



TESTING LABS

Chain of Custody Record

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Standard 24hr 48hr 72hr Other

Client Name:	Westchester Environmental LLC.			Project Name:	Hope Academy Charter
Address:	1248 Wrights Lane	Phone:	610-431-7545	Address:	Hope Academy Charter
	West Chester, PA 19380	Email:	nabraham@westchesterenviromental.com		601 Grand Ave, Asbury Park, NJ 07712
Contact Name:	Noel Abraham			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	HACS-1FL-POE-Faculty BR	11/02/21	10:30 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	Faculty BR
First	HACS-1FL-S-Boy's RR	11/02/21	10:31 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Boy's RR
First	HACS-1FL-S-Girl's RR	11/02/21	10:32 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Girl's RR
First	HACS-1FL-WC-Hall o/s 101	11/02/21	10:33 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 101
First	HACS-2FL-S-Boy's RR - 1	11/02/21	10:34 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 1
First	HACS-2FL-S-Boy's RR - 2	11/02/21	10:35 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 2
First	HACS-2FL-S-Boy's RR - 3	11/02/21	10:36 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 3
First	HACS-2FL-S-Girl's RR - 1	11/02/21	10:37 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 1
First	HACS-2FL-S-Girl's RR - 2	11/02/21	10:38 AM	NPA	009	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 2
First	HACS-2FL-S-Girl's RR - 3	11/02/21	10:39 AM	NPA	010	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 3

Relinquished by:

*BRITZ*

Date:

Time:

Received By:

*GRM - 572*

Date: 11/9/21 Temp °C: 22.0

Time: 12:06 Acceptable:  Y  N

Relinquished by:

*GRM - 572*

Date: 11/9/21 Temp °C: 19.0

Time: 12:30 Acceptable:  Y  N

Received in Lab By:

*GRM*

Date: 11/9/21 Temp °C: 19.0

Time: 12:30 Acceptable:  Y  N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted as CWC <input checked="" type="radio"/> Y <input type="radio"/> N	NPW = Non-Potable Water	P = Plastic
Use of containers marked for use for CWC compliance? <input checked="" type="radio"/> Y <input type="radio"/> N	Solid = Raw Sludge Discharge? <input type="radio"/> Y <input checked="" type="radio"/> N	G = Glass
All containers sealed <input checked="" type="radio"/> Y <input type="radio"/> N	SWW = Potable Sewer	O = Other
Tests with holding time <input checked="" type="radio"/> Y <input type="radio"/> N	SWA = State Drinking Water Act	
Did the WCA state flow of wastewater? <input checked="" type="radio"/> Y <input type="radio"/> N	Protein Sample	
	Sample Type Key - SWWA Sample Type	Preservative Key
	G = Grab	H = Sodium
	WHD = 8 Hour	Thiosulfate
	Composite	Acid
	24 HR = 24 Hour Composite	C = HCl
		H <sub>2</sub> SO <sub>4</sub>
		O = Other
		None
		Required
		NA =



1K03014  
Lisa F. Care



**TESTING LABS**

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

J 24hr 48hr 72hr Other

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Hope Academy Charter
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	Hope Academy Charter
	<b>West Chester, PA 19380</b>	Email:	nabraham@westchesterenviromental.com		601 Grand Ave, Asbury Park, NJ 07712
Contact Name:	<b>Noel Abraham</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	HACS-2FL-FS-Rm 206	11/02/21	10:40 AM	NPA	011	Pb EPA 200.8	1	PW	G	P	H	Rm 206
First	HACS-2FL-WC-Hall o/s 206	11/02/21	10:41 AM	NPA	012	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 206 1
First	HACS-2FL-WC-Hall o/s 206	11/02/21	10:42 AM	NPA	013	Pb EPA 200.8	1	PW	G	P	H	Hall o/s 206 2
First	HACS-2FL-S-Sink 208	11/02/21	10:43 AM	NPA	014	Pb EPA 200.8	1	PW	G	P	H	Sink 208
First	HACS-3FL-S-Boy's RR - 1	11/02/21	10:44 AM	NPA	015	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 1
First	HACS-3FL-S-Boy's RR - 2	11/02/21	10:45 AM	NPA	016	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 2
First	HACS-3FL-S-Boy's RR - 3	11/02/21	10:46 AM	NPA	017	Pb EPA 200.8	1	PW	G	P	H	Boy's RR - 3
First	HACS-3FL-S-Girl's RR - 1	11/02/21	10:47 AM	NPA	018	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 1
First	HACS-3FL-S-Girl's RR - 2	11/02/21	10:48 AM	NPA	019	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 2
First	HACS-3FL-S-Girl's RR - 3	11/02/21	10:49 AM	NPA	020	Pb EPA 200.8	1	PW	G	P	H	Girl's RR - 3

Relinquished by: *GRH* Date: \_\_\_\_\_ Time: \_\_\_\_\_

Received By: *GRH-SFL* Date: 11-9-21 Temp °C: 20 °C  
Time: 12:00 Acceptable  Y / N

Relinquished by: *GRH* Date: 11-9-21 Temp °C: 19 °C  
Time: 1:59 PM Acceptable  Y / N

Received in Lab By: \_\_\_\_\_ Date: \_\_\_\_\_ Temp °C: \_\_\_\_\_  
Time: \_\_\_\_\_ Acceptable  Y / N

Sample Conditions	Matrix Key	Bottle Type Key
<input checked="" type="checkbox"/> Y / N Sterility of COC <input checked="" type="checkbox"/> Y / N All containers meet all requirements <input checked="" type="checkbox"/> Y / N All containers meet all requirements <input checked="" type="checkbox"/> Y / N 45 ml VOA water from all faucets? <input checked="" type="checkbox"/> Y / N	<b>Matrix Key</b> NPW = Non Potable Water FWS = Flow Stoppage (Disturbance) PW = Potable Water SADA = Safe Drinking Water Act Plastic Surface <b>Sample Type Key - SADA sample Type</b> G = Grab 24 HR = 24 Hour Composite 24 HR = 24 Hour Composite D = Distribution E = Entry Point R = Raw C = Check S = Spouse M = Maximum Residence	<b>Bottle Type Key</b> P = Plastic G = Glass Q = Other <b>Preservative Key</b> H = Sodium Thiosulfate A = Ascorbic Acid C = VC MVA Q = Other None Received



1K03014  
Lisa F. Care

24hr 48hr 72hr Other



**TESTING LABS**

10377 MACARTHUR ROAD, READING, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

Client Name:	<b>Westchester Environmental LLC.</b>		Project Name:	Hope Academy Charter
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	
	<b>West Chester, PA 19380</b>	Email:	nabraham@westchesterenvironmental.com	
Contact Name:	<b>Noel Abraham</b>	Address:	601 Grand Ave, Asbury Park, NJ 07712	
		Payment / P.O. Info:		

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
First	HACS-3FL-WC-Hall o/s Boy's RR	11/02/21	10:50 AM	NPA	021	Pb EPA 200.8	1	PW	G	P	H	Hall o/s Boy's RR
First	HACS-4FL-S-Boy's RR	11/02/21	10:51 AM	NPA	022	Pb EPA 200.8	1	PW	G	P	H	Boy's RR
First	HACS-4FL-S-Girl's RR	11/02/21	10:52 AM	NPA	023	Pb EPA 200.8	1	PW	G	P	H	Girl's RR
First	HACS-4FL-KS-Kitchen	11/02/21	10:53 AM	NPA	024	Pb EPA 200.8	1	PW	G	P	H	Kitchen
First	HACS-5FL-S-Boy's RR	11/02/21	10:54 AM	NPA	025	Pb EPA 200.8	1	PW	G	P	H	Boy's RR
First	HACS-5FL-S-Girl's RR	11/02/21	10:55 AM	NPA	026	Pb EPA 200.8	1	PW	G	P	H	Girl's RR

Relinquished by: *GRH*

Date:

Time:

Received By: *GRH - STC*

Date: *11-9-21* Temp °C: *22.9C*

Time: *12:00* Acceptable *Y/N*

Relinquished by:

*GRH - STC*

Date: *11-4-21* Temp °C: *19.0C*

Time: *12:02* Acceptable *Y/N*

Received in Lab By:

*GRH*

Date:

Time:

Temp °C:

Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted as LOC <input checked="" type="checkbox"/>	NPW = Non-Potable Water	P = Plastic
Returned to customer match number as listed <input checked="" type="checkbox"/>	Dial = Raw Sludge, Dewatered Sludge, etc. (Reported as mg/L)	G = Glass
All containers intact <input checked="" type="checkbox"/>	PA = Plastic Bottle (Not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/>	SWDA = Safe Drinking Water Act Protocol Sample	Preservative Key
100 ml MQA vials free of headspace <input checked="" type="checkbox"/>	Sample Type Key	H = Retain
	G = Grab	Acid
	8 HC = 8 Hour Composite	A = Ascorbic
	R = Raw	H = HNO3
	C = Chloro	G = HCl
	S = Sulfur	ISO
	M = Minimum Residence	O = Other
	24 HC = 24 Hour Composite	None Required



### Results Report

Order ID: 1K03016

Westchester Environmental  
1248 Wrights Lane  
West Chester, PA 19380

Project: Hope Academy Charter - 500 Grand (Flushed)  
500 Grand Ave  
Asbury Park, NJ 07712

Attn: Noel Abraham

Regulatory ID:

Sample Number: 1K03016-05  
Collector: NPA

Site: HACS-1FL-S-Rm-206-F  
Collect Date: 11/02/2021 11:16 am

Sample ID: Rm-206-F  
Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/26/21	RPV	12/04/21 15:53	MKR
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 1K03016-06  
Collector: NPA

Site: HACS-2FL-S-Mens BR-F  
Collect Date: 11/02/2021 11:17 am

Sample ID: Mens BR-F  
Sample Type: F

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	1.71	µg/L	EPA 200.8	1.00	1	11/26/21	RPV	12/04/21 17:51	MKR
------	------	------	-----------	------	---	----------	-----	----------------	-----

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager II

Report Generated On: 12/06/2021 11:14 am  
STL\_Results Revision #1.9

1K03016  
Effective: 04/16/2020





1K03016  
Lisa F. Care



TESTING LABS

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

ard 24hr 48hr 72hr Other

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Hope Academy Charter
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	Hope Academy Charter
	<b>West Chester, PA 19380</b>	Email:	nabraham@westchesterenviromental.com		500 Grand Ave, Asbury Park, NJ 07712
Contact Name:	<b>Noel Abraham</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	HACS-1FL-S-O/S Janitors Clo	11/02/21	11:12 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	O/S Janitors Closet
Flush	HACS-1FL-S-Womens BR-F	11/02/21	11:13 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Womens BR
Flush	HACS-1FL-S-Mens BR-F	11/02/21	11:14 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Mens BR
Flush	HACS-1FL-NS-Nurse-F	11/02/21	11:15 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Nurse
Flush	HACS-1FL-S-Rm 206-F	11/02/21	11:16 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Rm 206
Flush	HACS-2FL-S-Mens BR-F	11/02/21	11:17 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Mens BR
Flush	HACS-2FL-S-Womens BR-F	11/02/21	11:18 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Womens BR
Flush	HACS-2FL-S-MPR-F	11/02/21	11:19 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Multi Purpose Room

Relinquished by:	Date:	Temp °C:
	Time:	Acceptable Y / N
Received By:	Date:	Temp °C:
	Time:	Acceptable Y / N
Relinquished by:	Date:	Temp °C:
	Time:	Acceptable Y / N
Received in Lab By:	Date:	Temp °C:
	Time:	Acceptable Y / N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
number of containers match number on COC? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Potable Sample	H = Sodium
	<b>Sample Type Key</b>	Thiosulphate Acid
	G = Grab	A = Ascorbic
	8 HC = 8 Hour Composite	H = HNO3
	E = Entry Point	S =
	R = Raw	H2SO4 OH = NaOH
	C = Check	O = Other
	S = Special	None Required
	M = Maximum	
	R = Residence	





1K03016  
Lisa F. Care



TESTING LABS

1037F MacArthur Road, Reading, PA 19605  
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

ard 24hr 48hr 72hr Other

Client Name:	<b>Westchester Environmental LLC.</b>			Project Name:	Hope Academy Charter
Address:	<b>1248 Wrights Lane</b>	Phone:	<b>610-431-7545</b>	Address:	Hope Academy Charter
	<b>West Chester, PA 19380</b>	Email:	nabraham@westchesterenvironmental.com		500 Grand Ave, Asbury Park, NJ 07712
Contact Name:	<b>Noel Abraham</b>			Payment / P.O. Info:	

Comments:

Flush / First Draw	Location Code	Date Sampled	Time Sampled	Samplers Initials	Westchester Field Sample #	Tests Requested	Bottle Quantity	Matrix	Sample Types	Bottle Type	Preservative	Sample Description / Site ID
Flush	HACS-1FL-S-O/S Janitors Clo	11/02/21	11:12 AM	NPA	001	Pb EPA 200.8	1	PW	G	P	H	O/S Janitors Closet
Flush	HACS-1FL-S-Womens BR-F	11/02/21	11:13 AM	NPA	002	Pb EPA 200.8	1	PW	G	P	H	Womens BR
Flush	HACS-1FL-S-Mens BR-F	11/02/21	11:14 AM	NPA	003	Pb EPA 200.8	1	PW	G	P	H	Mens BR
Flush	HACS-1FL-NS-Nurse-F	11/02/21	11:15 AM	NPA	004	Pb EPA 200.8	1	PW	G	P	H	Nurse
Flush	HACS-1FL-S-Rm 206-F	11/02/21	11:16 AM	NPA	005	Pb EPA 200.8	1	PW	G	P	H	Rm 206
Flush	HACS-2FL-S-Mens BR-F	11/02/21	11:17 AM	NPA	006	Pb EPA 200.8	1	PW	G	P	H	Mens BR
Flush	HACS-2FL-S-Womens BR-F	11/02/21	11:18 AM	NPA	007	Pb EPA 200.8	1	PW	G	P	H	Womens BR
Flush	HACS-2FL-S-MPR-F	11/02/21	11:19 AM	NPA	008	Pb EPA 200.8	1	PW	G	P	H	Multi Purpose Room

Relinquished by:

Date:

Time:

Received By:

Date: 11/9/21

Temp °C: 22 °C

Time: 1:00

Acceptable Y/N

Relinquished by:

Date: 11/9/21

Temp °C: 19 °C

Time: 1:50

Acceptable Y/N

Received in Lab By:

Date:

Temp °C:

Time:

Acceptable Y/N

Sample Conditions	Matrix Key	Bottle Type Key
Submitted w/ COC <input checked="" type="checkbox"/> Y/N	NPW = Non-Potable Water	P = Plastic
Number of containers match number on COC? <input checked="" type="checkbox"/> Y/N	Solid = Raw Sludge, Dewatered Sludge, soil, etc. (reported as mg/l)	G = Glass
All containers intact <input checked="" type="checkbox"/> Y/N	PW = Potable Water (not for SWDA compliance)	O = Other
Tests within holding times <input checked="" type="checkbox"/> Y/N	SWDA = Safe Drinking Water Act	<b>Preservative Key</b>
40 ml. VOA vials free of headspace? <input checked="" type="checkbox"/> Y/N	Potable Sample	H = Sodium
	<b>Sample Type Key</b>	Thiosulphate Acid
	G = Grab	A = Ascorbic
	8 HC = 8 Hour Composite	H = HNO3
	24 HC = 24 Hour Composite	C = HCl
		S = H2SO4
		O = Other
		OH = NaOH
		None Required
		NA =